2022 Water Quality Report for Osceola Township (Tamarack City)

This report covers the drinking water quality for Osceola Township (Tamarack City) for the 2022 calendar year. This information is a snapshot of the quality of the water that we provided to you in 2022. Included are details about where your water comes from, what it contains, and how it compares to United States Environmental Protection Agency (U.S. EPA) and state standards.

Your water comes from Upper Michigan Water, which is supplied by ground water from four wells. The company has been utilizing these wells since 1968. The water from this well supply is of good quality requiring only minimal treatment. The State performed an assessment of their source water in 2003 to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a seven-tiered scale from "very-low" to "very-high" based primarily on geologic sensitivity, water chemistry and contaminant sources. The susceptibility of our source is moderate.

There are no significant sources of contamination included in our water supply. We are making efforts to protect our sources by daily monitoring and monthly testing as well as distribution of the Drinking Water Protection Plan pamphlet and School Education.

If you would like to know more about the report, please contact Andrew Goldsworthy at (906) 370-9238 or Osceola Township, PO Box 437, Dollar Bay, MI 49922, (906) 482-8578, secretary@osceolatwp.com. You can also visit our website at www.osceolatownship.org.

Contaminants and their presence in water: Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (800-426-4791).

Vulnerability of sub-populations: Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Center for Disease Control guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791). Sources of drinking water: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from

Contaminants that may be present in source water include:

the presence of animals or from human activity.

- Microbial contaminants, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, can be naturally occurring or result from urban stormwater runoff,

- industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture and residential uses.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

In order to ensure that tap water is safe to drink, the U.S. EPA prescribes regulations that limit the levels of certain contaminants in water provided by public water systems. Federal Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

Information about lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Upper Michigan Water/Osceola Township is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you have a lead service line it is recommended that you run your water for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

Our water supply has approximately 38 lead service lines out of a total of 201 service lines.

Monitoring and Reporting to the Department of Environment, Great Lakes, and Energy (EGLE) Requirements: The State of Michigan and the U.S. EPA require us to test our water on a regular basis to ensure its safety. We met all the monitoring and reporting requirements for 2022.

We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies are available at Osceola Township office, 48545 Main Street, Dollar Bay, MI 49922

We invite public participation in decisions that affect drinking water quality. Tamarack City Utility Board Meetings are the 1st Wednesday of each month starting at 6:00 PM. The Osceola Township Board meetings are on the 2nd Wednesday of each month, starting at 6:15 PM.

For more information about your water, or the contents of this report, contact Andrew Goldsworthy at (906) 370-9238 or Osceola Township, PO Box 437, Dollar Bay, MI 49922, (906) 482-8578, secretary@osceolatwp.com. You can also visit our website at www.osceolatownship.org.

For more information about safe drinking water, visit the U.S. EPA at http://www.epa.gov/safewater.

The table below lists all the drinking water contaminants that we detected during the 2022 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2022. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

- Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- <u>Maximum Residual Disinfectant Level Goal (MRDLG)</u>: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- N/A: Not applicable; ND: not detectable at testing limit; ppm: parts per million or milligrams per liter; ppb: parts per billion or micrograms per liter; pCi/l: picocuries per liter (a measure of radioactivity); Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow

| Regulated Contaminant | MCL, TT, or MRDL | MCLG or MRDLG | Level Detected | Range | Year Sampled | Violation Yes/No | Typical Source of Contaminant |
|---|---------------------|---------------------|----------------------------|------------------|-----------------|-----------------------------|--|
| TTHM Total Trihalomethanes (ppb) | 80 | N/A | 38.8 | N/A | 2022 | No | Byproduct of drinking water disinfection |
| HAA5 Haloacetic Acids (ppb) | 60 | N/A | 7.2 | N/A | 2022 | No | Byproduct of drinking water disinfection |
| Chlorine ¹ (ppm) | 4 | 4 | 0.33 | 0.18-0.41 | 2022 | No | Water additive used to control microbes |
| Total Coliform | TT | N/A | 0 | N/A | 2022 | No | Naturally present in the environment |
| Inorganic Contaminant Subject to Action Levels (AL) | Action Level | MCLG | Your Water ² | Range of Results | Year Sampled | # of Samples Above AL | Typical Source of Contaminant |
| Lead (ppb) | 15 | 0 | 0 | 0-0.17 | 2022 | 0 | Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits |
| Copper (ppm) | 1.3 | 1.3 | 0.1 | 0-0.2 | 2022 | 0 | Corrosion of household plumbing systems; Erosion of natural deposits |

For Tamarack City: The Upper Michigan Water Company's Consumer Confidence Report is available in the Township Office or online at http://uppermichiganwater.com/water-quality/

For more information about safe drinking water, visit the U.S. Environmental Protection Agency at www.epa.gov/safewater/.

VIOLATIONS FOR 2022: Total Coliform monitoring

We failed to collect 3 total coliform bacteria samples for the month of April 2022. We collected all 3 required total coliform samples on May 10, 2022, which returned us to compliance for the bacteria monitoring violation. We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies are available at the Township Office.

¹ The chlorine "Level Detected" was calculated using a running annual average.

² Ninety (90) percent of the samples collected were at or below the level reported for our water.